



Measuring-Network of Wind Energy Institutes

20ld01

Mechanical Loads Proficiency Test

IECRE Public Report

Issue date November 2024

Technical coordinator: Martin Falk, windtest grevenbroich gmbh

Participants identities managed by MEASNET Secretariat

Contents

Preface	3
1. Introduction & Methodology	4
1.1. Standards in Scope.....	4
1.2. Methodology.....	4
1.3. Preliminary Line Choice.	4
2. Topics covered by the PT	5
2.1. Chunk data definition.	5
2.2. Databases	7
2.3. Calibration factors.....	7
2.4. Data filtering	8
2.5. Rain-flow parameters	9
2.6. Material exponent	9
3. Pass / Fail Criteria.....	10
4. Participant List.....	11
5. Proficiency Test Calendar	12
6. Results provided by participants	14
6.1. Data base: Capture Matrix (Task001).	14
6.2. Data base: Load Statistics (Task002).....	16
6.3. Data base: Yaw Misalignment (Task003).....	20
6.4. Data base: Frequency (Task004).....	23
6.5. Data base: Load Spectra (Task005).....	25
6.6. Data base: Damage equivalent loads (Task006).	28
6.7. Data base: Uncertainty (Task007).	31
6.8. Proficiency Test overall summary	40
6.9. Proficiency Test informative tasks summary.....	40
6.10. Proficiency Test mandatory tasks summary.....	41
7. IECRE Participants that passed the Proficiency Test	42
8. Conclusions an recommendations after Round 1	43
9. Conclusions an recommendations after Round 2	43
10. References.....	44

Preface

IEC Conformity Assessment Systems are globally recognized as giving consumers and industry more widely the confidence that a device or system meets or exceeds international standards.

[IECRE](#) is the global system for renewable energy conformity assessment and was established in 2014. Stakeholders in the system, those delivering conformity assessment activities, have to meet exacting criteria before being approved to operate.

In IECRE we have a global network of testing laboratories –known as RETLs– who meet the criteria in ISO/IEC 17025 for best management and measurement practice. An essential element of 17025 compliance is the demonstration of competence through inter laboratory or proficiency testing. Specifically for an international system with mutual acceptance of test results and certifications, proficiency testing is an integral element fostering the mutual trust which enable acceptance. All participants within the IECRE know and have proof that the system evaluates qualification to harmonized and aligned criteria.

IECRE has been working closely with [MEASNET](#), who is the provider of proficiency testing in the renewables sector.

IECRE and MEASNET are delighted to publish the final report for the most recent round of Loads proficiency testing and to make this available to all stakeholders and interested parties.

This report is the most comprehensive overview of Loads evaluation ever undertaken by almost every testing organization active in the renewables sector and it is hoped demonstrates that all laboratories in IECRE have proved their competence through a thorough and independent process.

We encourage the reports use in the renewables sector and welcome any comments or feedback.



Wolfram Zeitz
IECRE Executive Secretary



Alistair Mackinnon
IECRE Chair



Alejandro Martínez
MEASNET Vice Chairman

1. Introduction & Methodology

Within the framework of the MEASNET network internal quality evaluation program, the collaboration with the IECRE organization and the consideration of proficiency testing as a service offered to its customers, a Mechanical Loads proficiency test exercise was organized and performed.

This internal report is issued according to the contents described in the IECRE O.D. 551-17 [2]

1.1. Standards in Scope.

The participants performed the tasks according to the standard IEC 61400-13:2015 [1].

1.2. Methodology.

According to the IECRE O.D. 551-17 [2], the proficiency test was performed in two rounds.

Round 1 is conceived as a preparation phase intended to find the sources of the differences among the participants, and is restricted to type A participants.

Round 2 is open to type A and type B participants. The Pass and Fail criteria proposed below shall be used by IECRE to determine the proficiency of the laboratories belonging to the system.

1.3. Preliminary Line Choice.

The line choice is a set of instructions handled to the participants explaining which options, among those valid and present in the standard, have to be taken in order to improve the intercomparability of the results.

For this Mechanical Loads Proficiency Test one line choice has been defined.

Round 1 identifies a misunderstanding in creating load statistics of the tower bending moment because of the alignment and signal direction was mistakable.

The Round 1 team agreed to update the instructions with a position sketch for the tower strain gauges / signals (see picture 6.1) and to repeat the load statistic step for Round 1, in order to make sure that this misunderstanding source is solved.

2. Topics covered by the PT

2.1. Chunk data definition.

The input data for the PT follows the chunk data idea. The data were provided in form of text files (tabulator separated) and FAMOS files.

Database for step by step calculations:

1. Capture Matrix (task001)
 - Times series with scaled wind speed
 - Evaluated of mean value and turbulence intensity
2. Load Statistics (task002)
 - Times series with scaled load signal
 - Evaluation of mean, min, max and standard deviation
3. Yaw misalignment (task003)
 - Times series of scaled wind direction and nacelle position
 - Evaluation of misalignment, calculation the mean, min, max and standard deviation
4. Frequency calculations (task004)
 - Time series with several frequencies
 - Evaluation of the frequencies

Database after Rain-flow count and uncertainty calculations:

5. Load Spectra (task005)
 - Mean-Span-Rain-flow matrix
 - Evaluation of the load spectra and cumulative load spectra
6. Damage Equivalent Loads (task006)
 - Load spectra
 - Calculation of the DEL
7. Total Uncertainty (task007)
 - Table with:
 - i. No. of DS
 - ii. Wind speed [m/s]
 - iii. Load average [kNm]
 - iv. Load standard deviation [kNm]

- v. Wind speed uncertainty [m/s]
 - vi. Calibration uncertainty [kNm]
 - vii. Signal uncertainty [kNm]
- o Calculating of:
 - i. Total uncertainty
 - ii. Uncertainty of the BIN scatter
 - iii. Uncertainty of the x-axis quantity

2.2. Databases

For this Mechanical Loads Proficiency Test two databases were used. One was intended to be used for the mandatory step by step evaluation (compare to chapter 2.1 bullet points 1...4); the second one (compare to chapter 2.1 bullet points 5...7) contained the results of the rain-flow counting and the data for the uncertainty analysis.


2.3. Calibration factors

Table 2-1 Load channels

No.	Channel name	Offset	Slope
	MbTb000V (x-axis)	6,000 kNm	23,000 kNm/(mV/V)
	MbTb090V (y-axis)	11,000 kNm	24,000 kNm/(mV/V)
	MbBlFlatV	1,012 kNm	4,300 kNm/(mV/V)

Table 2-2 Strain gauge positions to geodetical north

No.	Description	Value	Unit
	MbTb000V (x-axis)	40	°
	MbTb090V (y-axis)	130	°



Picture 2-1: Assigning strain gauge signal/positions of tower base and north orientation referring to the IEC61400-13 Figure A.4

Table 2-3 Meteorological channels

No.	Channel name	Offset	Slope
	DirWndU	202.4 °	2.3 °/V
	VWndU	0.22 m/s	0.25 (m/s)/Hz
	VWndAlphaU	0	1

Table 2-4 Wind turbine channels

No.	Channel name	Offset	Slope
	PEIU	1,200 kW	190 kW/V
	StWtModU	-	-
	AgYawU	-40 °	220 °/V
	NRotU	0 rpm	2.9 rpm/V

Table 2-5 Output values status wind turbine mode

Status channel	Signal	Status
StWTModU	5 +- 0.5	grid connection
StWTModU	3.5 +- 2	system Ok

Table 2-6 Output values status signals

Status channel	Signal	Status
StGrid	0	no grid connection
StGrid	1	grid connection
StSysOk	0	system not ok
StSysOk	1	system ok

2.4. Data filtering

Filtering according to:

1. Sector of evaluation (exclude 0° to 182°)
2. Status grid connection
3. Status system ok
4. Pitch Type

2.5. Rain-flow parameters

For information only. The results of the rain-flow count for further analysis can be found in the above mentioned Excel sheet.

Table 2-7 Rain-flow parameters

Channel name	Resolution [kNm]	Range [kNm]
MbBlFlat	150	-2,000..4,000 kNm

Rainflow counting with full circles and residuals.

2.6. Material exponent

Table 2-8 Material exponent

Channel name	Material exponent
MbBlFlat	10

3. Pass / Fail Criteria

The RETLs belonging to IECRE must fulfil the following pass and fail criteria in order to be part of the IECRE system. These criteria are not mandatory for other participants.

The following aspects of the loads testing shall be covered by the proficiency test and the results from multiple items will be compared. Below there is a summary of the aspects and the pass/fail criteria to be applied:

Database for step by step calculations:

1. Capture Matrix (task001)
 - Any deviation is considered as a fail result.
2. Load Statistics (task002)
 - Maximum allowed difference is 0.5% from median value.
3. Yaw misalignment (task003)
 - Maximum allowed difference is 0.5% from median value.
4. Frequency calculations (task004)
 - Maximum allowed difference is 0.5% from median value.

For a successful participation of the PT it is mandatory to fulfil the criteria of the above mentioned tasks 1 to 4.

Database after Rain-flow count for DEL and uncertainty calculations as an informative evaluation with chunk data (compare to chapter 2.1):

- Load Spectra (task005)
 - Any deviation is considered as a fail result.
- Damage Equivalent Loads (R_i is the average value of the i^{th} range bin of the fatigue load spectrum) (task006)
 - Maximum allowed difference is 0.5% from median value.
- Total Uncertainty (task007).
 - Maximum allowed difference is 0.5% from median value.
- Uncertainty of the BIN scatter (task007).
 - Maximum allowed difference is 0.5% from median value.
- Uncertainty of the x-axis quantity (task007).
 - Maximum allowed difference is 0.5% from median value.
- Uncertainty of BIN averaged mean values (task007).
 - Maximum allowed difference is 0.5% from median value.

Deviation greater than 0.5% from median will be shaded in **orange**.

4. Participant List

The participants enlisted for Round 1 & Round 2 (type A participants) are, in alphabetical order:

TESTING LABORATORY
Anonymous laboratory 1 ¹
Aresse Engineering S.L.
Barlovento Recursos Naturales S.L.
Beijing CGC Certification Center Co., Ltd.
Center for Renewable Energy Sources and Saving - CRES
China Classification Society Certification Co., Ltd. - CCSC
China Electric Power Research Institute - CEPRI
Deutsche WindGuard Consulting GmbH
DNV Energy Systems Germany GmbH
DNV Maritime and Energy, S.L.U.
DTU Wind Energy
Fraunhofer-Institut für Windenergiesysteme - IWES
Nederlandse Organisatie voor Toegepast Natuurwetenschappelijk Onderzoek - TNO
Shanghai SERCAL New Energy Technology Co., Ltd.
UL International GmbH
Wind-consult GmbH
windtest grevenbroich gmbh

Participants registered for Round 2 only (type B participants), in alphabetical order:

TESTING LABORATORY
Anonymous laboratory 2 ¹
Goldwind Science & Technology Co., Ltd.
Korea Institute of Energy Research

¹ Anonymous laboratories 1 and 2 have not granted MEASNET permission to display their names on this list.

5. Proficiency Test Calendar

The following calendar describes the process of the Proficiency Test:

Preparation:

Application period deadline for Round 1	14.01.2022
Election of coordinator & participation appeals	14.01.2022 to 04.02.2022
Fees payment deadline for Round 1 participants	04.03.2022

Round 1:

Round 1 Instructions delivery	13.05.2022
Round 1 results submission deadline	17.06.2022
Round 1 data analysis from conductor	20.06.2022 to 24.06.2022
Round 1 results discussion	27.06.2022 to 08.07.2022

Second Round 1 - Load Statistics (task002)²

Round 1 Instructions delivery	07.10.2022
Round 1 results submission deadline	21.10.2022
Round 1 data analysis from conductor	24.10.2022 - 28.10.2022
Round 1 results discussion	03.11.2022

² Some issues were found and discussed about the load statistics task, so the group decided further investigate these issues on a voluntary participation basis.

Round 2:

Application period deadline for Round 2	07.10.2022
Fees payment deadline for Round 2 participants	30.11.2022
Round 2 Kick-off meeting	17.11.2022
Round 2 Instructions delivery	18.11.2022
Q&A period	21 to 25.11.2022
Round 2 results submission deadline*	12.12.2022 to 09.01.2023
Round 2 data analysis from conductor	10 to 17.01.2023
Round 2 results communication & room for non-technical corrections	30.01 to 10.02.2023
Round 2 final report creation	13 to 24.02.2023

* This period was defined to conceal claims of several participants.

6. Results provided by participants

6.1. Data base: Capture Matrix (Task001).

Determination of capture matrix, see also task001, chapter 2 ‘Topics covered by the PT’.

Result: No deviations found for this task.

Table 6-1: Capture matrix, data set count, wind speeds

	Data set count		Wind speeds [m/s]
Institute 0309	1	Institute 0309	10,22
Institute 2707	1	Institute 2707	10,22
Institute 3600	1	Institute 3600	10,22
Institute 3605	1	Institute 3605	10,22
Institute 3926	1	Institute 3926	10,22
Institute 4253	1	Institute 4253	10,22
Institute 4333	1	Institute 4333	10,22
Institute 4652	1	Institute 4652	10,22
Institute 4928	1	Institute 4928	10,22
Institute 4956	1	Institute 4956	10,22
Institute 4998	1	Institute 4998	10,22
Institute 5144	1	Institute 5144	10,22
Institute 5599	1	Institute 5599	10,22
Institute 7646	1	Institute 7646	10,22
Institute 7722	1	Institute 7722	10,22
Institute 8418	1	Institute 8418	10,22
Institute 8946	1	Institute 8946	10,20
Institute 9328	1	Institute 9328	10,22
Institute 9962	1	Institute 9962	10,22

Table 6-2: Capture matrix, results

Time series length	Normal power production																		
	10 minutes																		
WS (> to <=) [m/s] TI (> to <=) [%]	Institute 0309	Institute 2707	Institute 3600	Institute 3605	Institute 3926	Institute 4253	Institute 4333	Institute 4652	Institute 4928	Institute 4956	Institute 4998	Institute 5144	Institute 5599	Institute 7646	Institute 7722	Institute 8418	Institute 8946	Institute 9328	Institute 9962
<5																			
5..7																			
7..9	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1
9..11																			
11..13																			
13..15																			
15..17																			
17..19																			
19..21																			
21..23																			
23..25																			
25..27																			
27..29																			
>29																			
Number of turbulence BINs>= 3 data sets																			
Summary recorded data sets	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1	1

6.2. Data base: Load Statistics (Task002).

Determination of load statistics of tower bending nominal moments, see also task002, chapter 2 'Topics covered by the PT'.

The results have been compared relatively to the average and median of all participants' load statistics.

A limit value for deviation has been defined as $\pm 0.5\%$ of median.

Result: Participant 4253 and participant 4333 have greater deviations than 0.5% from median.

Table 6-3: Load statistics, data set count, wind speeds

	Data set count		Wind speeds [m/s]
Institute 0309	1	Institute 0309	10,22
Institute 2707	1	Institute 2707	10,22
Institute 3600	1	Institute 3600	10,22
Institute 3605	1	Institute 3605	10,22
Institute 3926	1	Institute 3926	10,22
Institute 4253	1	Institute 4253	10,22
Institute 4333	1	Institute 4333	10,22
Institute 4652	1	Institute 4652	10,22
Institute 4928	1	Institute 4928	10,22
Institute 4956	1	Institute 4956	10,22
Institute 4998	1	Institute 4998	10,22
Institute 5144	1	Institute 5144	10,22
Institute 5599	1	Institute 5599	10,22
Institute 7646	1	Institute 7646	10,22
Institute 7722	1	Institute 7722	10,22
Institute 8418	1	Institute 8418	10,22
Institute 8946	1	Institute 8946	10,22
Institute 9328	1	Institute 9328	10,22
Institute 9962	1	Institute 9962	10,22

Table 6-4: Load statistics, results

	Wind speed 10,22 m/s			
MbTbNormal	MbTbNormal maximum [kNm]	MbTbNormal average [kNm]	MbTbNormal minimum [kNm]	MbTbNormal standard deviation [kNm]
Institute 0309	12463,025	11576,263	10690,946	388,216
Institute 2707	12463,025	11576,263	10690,946	388,216
Institute 3600	12463,025	11576,263	10690,946	388,216
Institute 3605	12463,025	11576,263	10690,946	388,216
Institute 3926	12463,025	11576,263	10690,946	388,216
Institute 4253	-316,223	-890,718	-1562,476	272,005
Institute 4333	12334,580	11495,639	10678,434	364,680
Institute 4652	12463,025	11576,263	10690,946	388,216
Institute 4928	12463,025	11576,263	10690,946	388,216
Institute 4956	12463,025	11576,263	10690,946	388,216
Institute 4998	12463,025	11576,263	10690,946	388,216
Institute 5144	12463,025	11576,263	10690,946	388,216
Institute 5599	12463,025	11576,263	10690,945	388,216
Institute 7646	12463,025	11576,263	10690,946	388,216
Institute 7722	12463,030	11576,260	10690,950	388,210
Institute 8418	12463,025	11576,263	10690,945	388,216
Institute 8946	12463,025	11576,263	10690,946	388,216
Institute 9328	12463,026	11576,263	10690,946	388,216
Institute 9962	12463,025	11576,263	10690,946	388,216
Average	12455,890	11571,784	10690,251	386,908
Median	12463,025	11576,263	10690,946	388,216

Statistical outliers or insufficient information that are not considered for calculation of the average values.

Table 6-5: Load statistics, relative deviation to average

MbTbNormal	Wind speed 10,22 m/s			
	MbTbNormal maximum [%]	MbTbNormal average [%]	MbTbNormal minimum [%]	MbTbNormal standard deviation [%]
Institute 0309	0,06	0,04	0,01	0,34
Institute 2707	0,06	0,04	0,01	0,34
Institute 3600	0,06	0,04	0,01	0,34
Institute 3605	0,06	0,04	0,01	0,34
Institute 3926	0,06	0,04	0,01	0,34
Institute 4253	-102,54	-107,70	-114,62	-29,70
Institute 4333	-0,97	-0,66	-0,11	-5,75
Institute 4652	0,06	0,04	0,01	0,34
Institute 4928	0,06	0,04	0,01	0,34
Institute 4956	0,06	0,04	0,01	0,34
Institute 4998	0,06	0,04	0,01	0,34
Institute 5144	0,06	0,04	0,01	0,34
Institute 5599	0,06	0,04	0,01	0,34
Institute 7646	0,06	0,04	0,01	0,34
Institute 7722	0,06	0,04	0,01	0,34
Institute 8418	0,06	0,04	0,01	0,34
Institute 8946	0,06	0,04	0,01	0,34
Institute 9328	0,06	0,04	0,01	0,34
Institute 9962	0,06	0,04	0,01	0,34

Deviation greater than limit, see also task002, chapter 3 Pass / Fail Criteria.

Table 6-6: Load statistics, relative deviation to median

MbTbNormal	Wind speed 10,22 m/s			
	MbTbNormal maximum [%]	MbTbNormal average [%]	MbTbNormal minimum [%]	MbTbNormal standard deviation [%]
Institute 0309	0,00	0,00	0,00	0,00
Institute 2707	0,00	0,00	0,00	0,00
Institute 3600	0,00	0,00	0,00	0,00
Institute 3605	0,00	0,00	0,00	0,00
Institute 3926	0,00	0,00	0,00	0,00
Institute 4253	-102,54	-107,69	-114,61	-29,93
Institute 4333	-1,03	-0,70	-0,12	-6,06
Institute 4652	0,00	0,00	0,00	0,00
Institute 4928	0,00	0,00	0,00	0,00
Institute 4956	0,00	0,00	0,00	0,00
Institute 4998	0,00	0,00	0,00	0,00
Institute 5144	0,00	0,00	0,00	0,00
Institute 5599	0,00	0,00	0,00	0,00
Institute 7646	0,00	0,00	0,00	0,00
Institute 7722	0,00	0,00	0,00	0,00
Institute 8418	0,00	0,00	0,00	0,00
Institute 8946	0,00	0,00	0,00	0,00
Institute 9328	0,00	0,00	0,00	0,00
Institute 9962	0,00	0,00	0,00	0,00

Deviation greater than limit, see also task002, chapter 3 Pass / Fail Criteria.

6.3. Data base: Yaw Misalignment (Task003).

Determination of yaw misalignment, see also task003, chapter 2 'Topics covered by the PT'.

The results have been compared relatively to the average and median of all participants' yaw misalignments.

A limit value for deviations has been defined as +- 0.5 % of median.

Result: No deviations found for this task.

Table 6-7: Yaw misalignment, data set count, wind speeds

	Data set count		Wind speeds [m/s]
Institute 0309	1	Institute 0309	10,22
Institute 2707	1	Institute 2707	10,22
Institute 3600	1	Institute 3600	10,22
Institute 3605	1	Institute 3605	10,22
Institute 3926	1	Institute 3926	10,22
Institute 4253	1	Institute 4253	10,22
Institute 4333	1	Institute 4333	10,22
Institute 4652	1	Institute 4652	10,22
Institute 4928	1	Institute 4928	10,22
Institute 4956	1	Institute 4956	10,22
Institute 4998	1	Institute 4998	10,22
Institute 5144	1	Institute 5144	10,22
Institute 5599	1	Institute 5599	10,22
Institute 7646	1	Institute 7646	10,22
Institute 7722	1	Institute 7722	10,22
Institute 8418	1	Institute 8418	10,22
Institute 8946	1	Institute 8946	10,22
Institute 9328	1	Institute 9328	10,22
Institute 9962	1	Institute 9962	10,22

Table 6-8: Yaw misalignment, results

Yaw misalignment	Yaw misalignment maximum [°]	Yaw misalignment average [°]	Yaw misalignment minimum [°]	Yaw misalignment standard deviation [°]
Institute 0309	9,987	9,585	9,182	0,231
Institute 2707	9,987	9,585	9,182	0,231
Institute 3600	9,987	9,585	9,182	0,231
Institute 3605	9,987	9,585	9,182	0,231
Institute 3926	9,988	9,586	9,183	0,231
Institute 4253	9,987	9,585	9,182	0,231
Institute 4333	9,987	9,585	9,182	0,231
Institute 4652	9,987	9,585	9,182	0,231
Institute 4928	9,987	9,585	9,182	0,231
Institute 4956	9,988	9,586	9,183	0,231
Institute 4998	9,987	9,585	9,182	0,231
Institute 5144	9,987	9,585	9,182	0,231
Institute 5599	9,987	9,585	9,182	0,231
Institute 7646	9,987	9,585	9,182	0,231
Institute 7722	9,987	9,585	9,182	0,231
Institute 8418	9,988	9,585	9,183	0,231
Institute 8946	9,987	9,585	9,182	0,231
Institute 9328	9,988	9,586	9,183	0,231
Institute 9962	9,987	9,585	9,182	0,231
Average	9,987	9,585	9,182	0,231
Median	9,987	9,585	9,182	0,231

Table 6-9: Yaw misalignment, relative deviation to average

Yaw misalignment	Yaw misalignment maximum [%]	Yaw misalignment average [%]	Yaw misalignment minimum [%]	Yaw misalignment standard deviation [%]
Institute 0309	0,00	0,00	0,00	0,00
Institute 2707	0,00	0,00	0,00	0,00
Institute 3600	0,00	0,00	0,00	0,00
Institute 3605	0,00	0,00	0,00	0,00
Institute 3926	0,00	0,00	0,00	0,00
Institute 4253	0,00	0,00	0,00	0,00
Institute 4333	0,00	0,00	0,00	0,00
Institute 4652	0,00	0,00	0,00	0,00
Institute 4928	0,00	0,00	0,00	0,00
Institute 4956	0,00	0,00	0,00	0,00
Institute 4998	0,00	0,00	0,00	0,00
Institute 5144	0,00	0,00	0,00	-0,04
Institute 5599	0,00	0,00	0,00	0,00
Institute 7646	0,00	0,00	0,00	0,00
Institute 7722	0,00	0,00	0,00	0,00
Institute 8418	0,01	0,00	-0,01	-0,04
Institute 8946	0,00	0,00	0,00	0,00
Institute 9328	0,00	0,00	0,00	0,00
Institute 9962	0,00	0,00	0,00	0,00

Table 6-10: Yaw misalignment, relative deviation to median

Yaw misalignment	Yaw misalignment maximum [%]	Yaw misalignment average [%]	Yaw misalignment minimum [%]	Yaw misalignment standard deviation [%]
Institute 0309	0,00	0,00	0,00	0,00
Institute 2707	0,00	0,00	0,00	0,00
Institute 3600	0,00	0,00	0,00	0,00
Institute 3605	0,00	0,00	0,00	0,00
Institute 3926	0,00	0,00	0,00	0,00
Institute 4253	0,00	0,00	0,00	0,00
Institute 4333	0,00	0,00	0,00	0,00
Institute 4652	0,00	0,00	0,00	0,00
Institute 4928	0,00	0,00	0,00	0,00
Institute 4956	0,00	0,00	0,00	0,00
Institute 4998	0,00	0,00	0,00	0,00
Institute 5144	0,00	0,00	0,00	-0,04
Institute 5599	0,00	0,00	0,00	0,00
Institute 7646	0,00	0,00	0,00	0,00
Institute 7722	0,00	0,00	0,00	0,00
Institute 8418	0,01	0,00	-0,01	-0,04
Institute 8946	0,00	0,00	0,00	0,00
Institute 9328	0,00	0,00	0,00	0,00
Institute 9962	0,00	0,00	0,00	0,00

6.4. Data base: Frequency (Task004).

Determination of frequency of tower bending normal moments, see also task004, chapter 2 'Topics covered by the PT'.

The results have been compared relatively to the average and median of all participant's frequencies.

A limit value for deviations has been defined as +- 0.5 % of median.

Result: Participant 4333 has greater deviations than 0.5% from median.

Table 6-11: frequency, results

MbTb000	Frequency 1 [Hz]	Frequency 2 [Hz]	Frequency 3 [Hz]	Frequency 4 [Hz]	Frequency 5 [Hz]
Institute 0309	0,29910	0,50050	1,00100	1,99890	0,00000
Institute 2707	0,29907	0,50049	1,00098	1,99890	0,00000
Institute 3600	0,29910	0,50049	1,00098	1,99890	0,00000
Institute 3605	0,30000	0,50000	1,00000	2,00000	0,00000
Institute 3926	0,30000	0,50000	1,00000	2,00000	0,00000
Institute 4253	0,30059	0,50048	0,99945	2,00042	0,00000
Institute 4333	0,29300	0,50700	0,98700	2,00100	0,00000
Institute 4652	0,30000	0,50000	1,00000	2,00000	0,00000
Institute 4928	0,30000	0,50000	1,00000	2,00000	0,00000
Institute 4956	0,30000	0,50000	1,00000	2,00000	0,00000
Institute 4998	0,29903	0,50037	1,00098	2,00195	0,00000
Institute 5144	0,29910	0,50050	1,00100	1,99900	0,00000
Institute 5599	0,29907	0,50049	1,00098	1,99890	0,00000
Institute 7646	0,30000	0,50000	1,00000	2,00000	0,00000
Institute 7722	0,30000	0,50000	1,00000	2,00000	0,00000
Institute 8418	0,29907	0,50049	1,00098	2,00195	0,00000
Institute 8946	0,30000	0,50000	1,00000	2,00000	0,00000
Institute 9328	0,30000	0,50000	1,00000	2,00000	0,00000
Institute 9962	0,30000	0,50000	1,00000	2,00000	0,00000
Average	0,29924331	0,50056468	0,99971576	1,99994146	0,00000000
Median	0,30000000	0,50037040	1,00000000	2,00000000	0,00000000

Table 6-12: frequency, relative deviation to average

MbTb000	Frequency 1 [Hz]	Frequency 2 [Hz]	Frequency 3 [Hz]	Frequency 4 [Hz]
Institute 0309	-0,04788943	-0,01292064	0,12846008	-0,05207453
Institute 2707	-0,05715760	-0,01526175	0,12611566	-0,05200617
Institute 3600	-0,04788943	-0,01491838	0,12615942	-0,05207453
Institute 3605	0,25286918	-0,11280783	0,02843164	0,00292708
Institute 3926	0,25286918	-0,11280783	0,02843164	0,00292708
Institute 4253	0,45003315	-0,01691613	-0,02658399	0,02392770
Institute 4333	-2,08636444	1,28561286	-1,27193797	0,05292855
Institute 4652	0,25286918	-0,11280783	0,02843164	0,00292708
Institute 4928	0,25286918	-0,11280783	0,02843164	0,00292708
Institute 4956	0,25286918	-0,11280783	0,02843164	0,00292708
Institute 4998	-0,07148227	-0,03881140	0,12665956	0,10052994
Institute 5144	-0,04788943	-0,01292064	0,12846008	-0,04707438
Institute 5599	-0,05715781	-0,01526180	0,12611566	-0,05200617
Institute 7646	0,25286918	-0,11280783	0,02843164	0,00292708
Institute 7722	0,25286918	-0,11280783	0,02843164	0,00292708
Institute 8418	-0,05715614	-0,01526200	0,12611941	0,10058494
Institute 8946	0,25286918	-0,11280783	0,02843164	0,00292708
Institute 9328	0,25286918	-0,11280783	0,02843164	0,00292708
Institute 9962	0,25286918	-0,11280783	0,02843164	0,00292708

Deviation greater than limit, see also task003, chapter 3 Pass / Fail Criteria

Table 6-13: frequency, relative deviation to median

MbTb000	Frequency 1 [Hz]	Frequency 2 [Hz]	Frequency 3 [Hz]	Frequency 4 [Hz]
Institute 0309	-0,30000000	0,02590081	0,10000000	-0,05500000
Institute 2707	-0,30924479	0,02355880	0,09765625	-0,05493164
Institute 3600	-0,30000000	0,02390229	0,09770000	-0,05500000
Institute 3605	0,00000000	-0,07402516	0,00000000	0,00000000
Institute 3926	0,00000000	-0,07402516	0,00000000	0,00000000
Institute 4253	0,19666667	0,02190377	-0,05500000	0,02100000
Institute 4333	-2,33333333	1,32493849	-1,30000000	0,05000000
Institute 4652	0,00000000	-0,07402516	0,00000000	0,00000000
Institute 4928	0,00000000	-0,07402516	0,00000000	0,00000000
Institute 4956	0,00000000	-0,07402516	0,00000000	0,00000000
Institute 4998	-0,32353333	0,00000000	0,09820000	0,09760000
Institute 5144	-0,30000000	0,02590081	0,10000000	-0,05000000
Institute 5599	-0,30924500	0,02355875	0,09765625	-0,05493164
Institute 7646	0,00000000	-0,07402516	0,00000000	0,00000000
Institute 7722	0,00000000	-0,07402516	0,00000000	0,00000000
Institute 8418	-0,30924333	0,02355855	0,09766000	0,09765500
Institute 8946	0,00000000	-0,07402516	0,00000000	0,00000000
Institute 9328	0,00000000	-0,07402516	0,00000000	0,00000000
Institute 9962	0,00000000	-0,07402516	0,00000000	0,00000000

Deviation greater than limit, see also task003, chapter 3 'Pass / Fail Criteria'.

6.5. Data base: Load Spectra (Task005).

Determination of load spectra of blade flat bending moment of a given rain-flow count, see also task005, chapter 2 'Topics covered by the PT'.

Any deviation is considered as a fail result.

Result:

- Count result: Participant 9328 has a deviation compared to the majority.
- Cumulative count: Participant 4333, participant 7646 and participant 9328 have a deviation compared to the majority.

Table 6-14: Load spectra, data set count, wind speeds

	Data set count		Wind speeds [m/s]
Institute 0309	1	Institute 0309	10,22
Institute 2707	1	Institute 2707	10,22
Institute 3600	1	Institute 3600	10,22
Institute 3605	1	Institute 3605	10,22
Institute 3926	1	Institute 3926	10,22
Institute 4253	1	Institute 4253	10,22
Institute 4333	1	Institute 4333	10,22
Institute 4652	1	Institute 4652	10,22
Institute 4928	1	Institute 4928	10,22
Institute 4956	1	Institute 4956	10,22
Institute 4998	1	Institute 4998	10,22
Institute 5144	1	Institute 5144	10,22
Institute 5599	1	Institute 5599	10,22
Institute 7646	1	Institute 7646	10,22
Institute 7722	1	Institute 7722	10,22
Institute 8418	1	Institute 8418	10,22
Institute 8946	1	Institute 8946	10,20
Institute 9328	1	Institute 9328	10,22
Institute 9962	1	Institute 9962	10,22

Table 6-15: load spectra count, results

Span [kNm] (>= to <)	Count																			
	Institute 0309	Institute 2707	Institute 3600	Institute 3605	Institute 3926	Institute 4253	Institute 4333	Institute 4652	Institute 4928	Institute 4956	Institute 4998	Institute 5144	Institute 5599	Institute 7646	Institute 7722	Institute 8418	Institute 8946	Institute 9328	Institute 9962	
0 to 150	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
150 to 300	1999,5	1999,5	1999,5	1999,5	1999,5	1999,5	1999,5	1999,5	1999,5	1999,5	1999,5	1999,5	1999,5	1999,5	1999,5	1999,5	1999,5	1999,5	1999,5	1999,5
300 to 450	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
450 to 600	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
600 to 750	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
750 to 900	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
900 to 1050	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
1050 to 1200	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
1200 to 1350	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
1350 to 1500	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
1500 to 1650	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
1650 to 1800	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
1800 to 1950	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
1950 to 2100	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
2100 to 2250	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
2250 to 2400	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
2400 to 2550	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
2550 to 2700	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
2700 to 2850	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
2850 to 3000	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
3000 to 3150	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
3150 to 3300	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
3300 to 3450	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
3450 to 3600	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
3600 to 3750	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
3750 to 3900	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
3900 to 4050	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
4050 to 4200	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
4200 to 4350	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
4350 to 4500	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
4500 to 4650	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
4650 to 4800	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
4800 to 4950	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
4950 to 5100	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
5100 to 5250	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
5250 to 5400	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
5400 to 5550	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
5550 to 5700	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
5700 to 5850	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0
5850 to 6000	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0

Deviation to majority, see also task005, chapter 3 ‘Pass / Fail Criteria’.

Table 6-16: load spectra cumulative count, results

No.	Span [kNm] (>=)	Cumulative Count																		
		Institute 0309	Institute 2707	Institute 3600	Institute 3605	Institute 3926	Institute 4253	Institute 4333	Institute 4652	Institute 4928	Institute 4956	Institute 4998	Institute 5144	Institute 5599	Institute 7646	Institute 7722	Institute 8418	Institute 8946	Institute 9328	Institute 9962
0	0,00	1999,5	1999,5	1999,5	1999,5	1999,5	1999,5	0,0	1999,5	1999,5	1999,5	1999,5	1999,5	1999,5	0,0	1999,5	1999,5	1999,5	1999,5	1999,5
1	0,25	1999,5	1999,5	1999,5	1999,5	1999,5	1999,5	1999,5	1999,5	1999,5	1999,5	1999,5	1999,5	1999,5	1999,5	1999,5	1999,5	1999,5	1999,5	1999,5
2	0,50	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
3	0,75	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
4	1,00	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
5	1,25	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
6	1,50	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
7	1,75	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
8	2,00	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
9	2,25	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
10	2,50	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
11	2,75	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
12	3,00	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
13	3,25	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
14	3,50	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
15	3,75	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
16	4,00	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
17	4,25	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
18	4,50	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
19	4,75	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
20	5,00	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
21	5,25	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
22	5,50	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
23	5,75	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
24	6,00	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
25	6,25	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
26	6,50	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
27	6,75	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
28	7,00	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
29	7,25	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
30	7,50	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
31	7,75	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
32	8,75	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
33	9,75	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
34	10,75	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
35	11,75	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
36	12,75	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
37	13,75	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
38	14,75	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0
39	15,75	0,0	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	1999,5	0,0	0,0	0,0	0,0	0,0	0,0

Deviation to majority, see also task005, chapter 3 ‘Pass / Fail Criteria’.

6.6. Data base: Damage equivalent loads (Task006).

Determination of damage equivalent loads (DEL) of blade flat bending moments ($m=10$) of a given rain-flow count, see also task006, chapter 2 'Topics covered by the PT'.

The results have been compared relatively to the average and median of all participants' DEL.

A limit value for deviations has been defined as $\pm 0.5\%$ of median.

Result: Participant 4333 and participant 9962 have greater deviations than 0.5% from median.

Table 6-17: DEL, data set count, wind speeds

	Data set count		Wind speeds [m/s]
Institute 0309	1	Institute 0309	10,22
Institute 2707	1	Institute 2707	10,22
Institute 3600	1	Institute 3600	10,22
Institute 3605	1	Institute 3605	10,22
Institute 3926	1	Institute 3926	10,22
Institute 4253	1	Institute 4253	10,22
Institute 4333	1	Institute 4333	10,22
Institute 4652	1	Institute 4652	10,22
Institute 4928	1	Institute 4928	10,22
Institute 4956	1	Institute 4956	10,22
Institute 4998	1	Institute 4998	10,22
Institute 5144	1	Institute 5144	10,22
Institute 5599	1	Institute 5599	10,22
Institute 7646	1	Institute 7646	10,22
Institute 7722	1	Institute 7722	10,22
Institute 8418	1	Institute 8418	10,22
Institute 8946	1	Institute 8946	10,22
Institute 9328	1	Institute 9328	10,22
Institute 9962	1	Institute 9962	10,22

Table 6-18: DEL, results

	Wind speed [m/s]
DEL MbBIFlat [kNm]	10,22
Institute 0309	253,781
Institute 2707	253,781
Institute 3600	253,781
Institute 3605	253,781
Institute 3926	253,781
Institute 4253	253,781
Institute 4333	237,652
Institute 4652	253,781
Institute 4928	253,781
Institute 4956	253,781
Institute 4998	253,781
Institute 5144	253,781
Institute 5599	253,781
Institute 7646	253,781
Institute 7722	253,781
Institute 8418	253,780
Institute 8946	253,781
Institute 9328	253,790
Institute 9962	257,198
Average	253,782
Median	253,781

Statistical outliers or insufficient info that are not considered for calculation of the average values.

Table 6-19: DEL, deviation to average

	Wind speed [m/s]
DEL MbBIFlat [%]	10,22
Institute 0309	0,00
Institute 2707	0,00
Institute 3600	0,00
Institute 3605	0,00
Institute 3926	0,00
Institute 4253	0,00
Institute 4333	-6,36
Institute 4652	0,00
Institute 4928	0,00
Institute 4956	0,00
Institute 4998	0,00
Institute 5144	0,00
Institute 5599	0,00
Institute 7646	0,00
Institute 7722	0,00
Institute 8418	0,00
Institute 8946	0,00
Institute 9328	0,00
Institute 9962	1,35

Deviation greater than limit, see also task007, chapter 3 'Pass / Fail Criteria'.

Table 6-20: DEL, deviation to median

	Wind speed [m/s]
DEL MbBIFlat [%]	10,22
Institute 0309	0,00
Institute 2707	0,00
Institute 3600	0,00
Institute 3605	0,00
Institute 3926	0,00
Institute 4253	0,00
Institute 4333	-6,36
Institute 4652	0,00
Institute 4928	0,00
Institute 4956	0,00
Institute 4998	0,00
Institute 5144	0,00
Institute 5599	0,00
Institute 7646	0,00
Institute 7722	0,00
Institute 8418	0,00
Institute 8946	0,00
Institute 9328	0,00
Institute 9962	1,35

Deviation greater than limit, see also task007, chapter 3 'Pass / Fail Criteria'.

6.7. Data base: Uncertainty (Task007).

Determination of uncertainties. Informative only, see also task007, chapter 2 ‘Topics covered by the PT’.

A limit value for deviations has been defined as +- 0.5 % of median.

Result:

- BIN8: Participant 9328 has greater deviations than 0.5% from median.
- BIN9: No deviations found for this task.
- BIN10: Participant 3926, participant 4956, participant 8418 and participant 8946 have greater deviations than 0.5% from median.

Table 6-21: Uncertainty, BIN 8 results

Uncertainties	BIN No. 8			
	Total Uncertainty [kNm]	BIN scatter Uncertainty [kNm]	X-axis quantity Uncertainty [kNm]	BIN averaged mean values Uncertainty [kNm]
Institute 0309	60,356	35,381	31,540	76,742
Institute 2707	60,356	35,381	31,540	76,742
Institute 3600	60,356	35,381	31,540	76,742
Institute 3605	60,356	35,381	31,540	76,742
Institute 3926	60,356	35,381	31,540	76,742
Institute 4253	60,356	35,381	31,540	76,742
Institute 4333	60,356	35,381	31,540	76,742
Institute 4652	60,356	35,381	31,540	76,742
Institute 4928	60,356	35,381	31,540	76,742
Institute 4956	60,356	35,381	31,540	76,742
Institute 4998	60,356	35,381	31,540	76,742
Institute 5144	60,356	35,381	31,540	76,742
Institute 5599	60,356	35,381	31,540	76,742
Institute 7646	60,356	35,381	31,540	76,742
Institute 7722	60,356	35,381	31,540	76,742
Institute 8418	60,356	35,381	31,540	76,742
Institute 8946	60,356	35,381	31,540	76,742
Institute 9328	60,356	35,381	-	-
Institute 9962	60,356	35,381	31,540	76,742
Average	60,356	35,381	31,540	76,742
Median	60,356	35,381	31,540	76,742

Table 6-22: Uncertainty, BIN 8 relative deviation to average

Uncertainties	BIN No. 8			
	Total uncertainty [kNm]	BIN scatter Uncertainty [kNm]	X-axis quantity Uncertainty [kNm]	BIN averaged mean values Uncertainty [kNm]
Institute 0309	0,00	0,00	0,00	0,00
Institute 2707	0,00	0,00	0,00	0,00
Institute 3600	0,00	0,00	0,00	0,00
Institute 3605	0,00	0,00	0,00	0,00
Institute 3926	0,00	0,00	0,00	0,00
Institute 4253	0,00	0,00	0,00	0,00
Institute 4333	0,00	0,00	0,00	0,00
Institute 4652	0,00	0,00	0,00	0,00
Institute 4928	0,00	0,00	0,00	0,00
Institute 4956	0,00	0,00	0,00	0,00
Institute 4998	0,00	0,00	0,00	0,00
Institute 5144	0,00	0,00	0,00	0,00
Institute 5599	0,00	0,00	0,00	0,00
Institute 7646	0,00	0,00	0,00	0,00
Institute 7722	0,00	0,00	0,00	0,00
Institute 8418	0,00	0,00	0,00	0,00
Institute 8946	0,00	0,00	0,00	0,00
Institute 9328	0,00	0,00	na	na
Institute 9962	0,00	0,00	0,00	0,00

Deviation greater than limit, see also task007, chapter 3 'Pass / Fail Criteria'.

Table 6-23: Uncertainty, BIN 8 relative deviation to median

Uncertainties	BIN No. 8			
	Total uncertainty [kNm]	BIN scatter Uncertainty [kNm]	X-axis quantity Uncertainty [kNm]	BIN averaged mean values Uncertainty [kNm]
Institute 0309	0,00	0,00	0,00	0,00
Institute 2707	0,00	0,00	0,00	0,00
Institute 3600	0,00	0,00	0,00	0,00
Institute 3605	0,00	0,00	0,00	0,00
Institute 3926	0,00	0,00	0,00	0,00
Institute 4253	0,00	0,00	0,00	0,00
Institute 4333	0,00	0,00	0,00	0,00
Institute 4652	0,00	0,00	0,00	0,00
Institute 4928	0,00	0,00	0,00	0,00
Institute 4956	0,00	0,00	0,00	0,00
Institute 4998	0,00	0,00	0,00	0,00
Institute 5144	0,00	0,00	0,00	0,00
Institute 5599	0,00	0,00	0,00	0,00
Institute 7646	0,00	0,00	0,00	0,00
Institute 7722	0,00	0,00	0,00	0,00
Institute 8418	0,00	0,00	0,00	0,00
Institute 8946	0,00	0,00	0,00	0,00
Institute 9328	0,00	0,00	na	na
Institute 9962	0,00	0,00	0,00	0,00

Deviation greater than limit, see also task007, chapter 3 'Pass / Fail Criteria'.

Table 6-24: Uncertainty, BIN 9 results

Uncertainties	BIN No. 9			
	Total Uncertainty [kNm]	BIN scatter Uncertainty [kNm]	X-axis quantity Uncertainty [kNm]	BIN averaged mean values Uncertainty [kNm]
Institute 0309	60,356	56,161	31,540	88,270
Institute 2707	60,356	56,161	31,540	88,270
Institute 3600	60,356	56,161	31,540	88,270
Institute 3605	60,356	56,161	31,540	88,270
Institute 3926	60,356	56,161	31,540	88,270
Institute 4253	60,356	56,161	31,540	88,270
Institute 4333	60,356	56,161	31,540	88,270
Institute 4652	60,356	56,161	31,540	88,270
Institute 4928	60,356	56,161	31,540	88,270
Institute 4956	60,356	56,161	31,540	88,270
Institute 4998	60,356	56,161	31,540	88,270
Institute 5144	60,356	56,161	31,540	88,270
Institute 5599	60,356	56,161	31,540	88,270
Institute 7646	60,356	56,161	31,540	88,270
Institute 7722	60,356	56,161	31,540	88,270
Institute 8418	60,356	56,161	31,540	88,270
Institute 8946	60,356	56,161	31,540	88,270
Institute 9328	60,356	56,161	31,540	88,270
Institute 9962	60,356	56,161	31,540	88,270
Average	60,356	56,161	31,540	88,270
Median	60,356	56,161	31,540	88,270

Table 6-25: Uncertainty, BIN 9 relative deviation to average

Uncertainties	BIN No. 9			
	Total uncertainty [kNm]	BIN scatter Uncertainty [kNm]	X-axis quantity Uncertainty [kNm]	BIN averaged mean values Uncertainty [kNm]
Institute 0309	0,00	0,00	0,00	0,00
Institute 2707	0,00	0,00	0,00	0,00
Institute 3600	0,00	0,00	0,00	0,00
Institute 3605	0,00	0,00	0,00	0,00
Institute 3926	0,00	0,00	0,00	0,00
Institute 4253	0,00	0,00	0,00	0,00
Institute 4333	0,00	0,00	0,00	0,00
Institute 4652	0,00	0,00	0,00	0,00
Institute 4928	0,00	0,00	0,00	0,00
Institute 4956	0,00	0,00	0,00	0,00
Institute 4998	0,00	0,00	0,00	0,00
Institute 5144	0,00	0,00	0,00	0,00
Institute 5599	0,00	0,00	0,00	0,00
Institute 7646	0,00	0,00	0,00	0,00
Institute 7722	0,00	0,00	0,00	0,00
Institute 8418	0,00	0,00	0,00	0,00
Institute 8946	0,00	0,00	0,00	0,00
Institute 9328	0,00	0,00	0,00	0,00
Institute 9962	0,00	0,00	0,00	0,00

Table 6-26: Uncertainty, BIN 9 relative deviation to median

Uncertainties	BIN No. 9			
	Total uncertainty [kNm]	BIN scatter Uncertainty [kNm]	X-axis quantity Uncertainty [kNm]	BIN averaged mean values Uncertainty [kNm]
Institute 0309	0,00	0,00	0,00	0,00
Institute 2707	0,00	0,00	0,00	0,00
Institute 3600	0,00	0,00	0,00	0,00
Institute 3605	0,00	0,00	0,00	0,00
Institute 3926	0,00	0,00	0,00	0,00
Institute 4253	0,00	0,00	0,00	0,00
Institute 4333	0,00	0,00	0,00	0,00
Institute 4652	0,00	0,00	0,00	0,00
Institute 4928	0,00	0,00	0,00	0,00
Institute 4956	0,00	0,00	0,00	0,00
Institute 4998	0,00	0,00	0,00	0,00
Institute 5144	0,00	0,00	0,00	0,00
Institute 5599	0,00	0,00	0,00	0,00
Institute 7646	0,00	0,00	0,00	0,00
Institute 7722	0,00	0,00	0,00	0,00
Institute 8418	0,00	0,00	0,00	0,00
Institute 8946	0,00	0,00	0,00	0,00
Institute 9328	0,00	0,00	0,00	0,00
Institute 9962	0,00	0,00	0,00	0,00

Table 6-27: Uncertainty, BIN 10 results

Uncertainties	BIN No. 10			
	Total Uncertainty [kNm]	BIN scatter Uncertainty [kNm]	X-axis quantity Uncertainty [kNm]	BIN averaged mean values Uncertainty [kNm]
Institute 0309	60,356	45,334	-108,901	132,504
Institute 2707	60,356	45,334	-108,901	132,504
Institute 3600	60,356	45,334	-108,901	132,504
Institute 3605	60,356	45,334	-108,901	132,504
Institute 3926	60,356	45,334	108,901	132,504
Institute 4253	60,356	45,334	-108,901	132,504
Institute 4333	60,356	45,334	-108,901	132,504
Institute 4652	60,356	45,334	-108,901	132,504
Institute 4928	60,356	45,334	-108,901	132,504
Institute 4956	60,356	45,334	108,901	132,504
Institute 4998	60,356	45,334	-108,901	132,504
Institute 5144	60,356	45,334	-108,901	132,504
Institute 5599	60,356	45,334	-108,901	132,504
Institute 7646	60,356	45,334	-108,901	132,504
Institute 7722	60,356	45,334	-108,901	132,504
Institute 8418	60,356	45,334	108,901	132,504
Institute 8946	60,356	45,334	108,901	132,504
Institute 9328	60,356	45,334	-108,901	132,504
Institute 9962	60,356	45,334	-108,901	132,504
Average	60,356	45,334	-108,901	132,504
Median	60,356	45,334	-108,901	132,504

Applying the equation stated in the standard, the values are negative in this case. Outliers where due to the “absolute function” of some participants where the result will be always positive. Due to the characteristics of uncertainty a positive value is correct as well.

Table 6-28: Uncertainty, BIN 10 relative deviation to average

Uncertainties	BIN No. 10			
	Total uncertainty [kNm]	BIN scatter Uncertainty [kNm]	X-axis quantity Uncertainty [kNm]	BIN averaged mean values Uncertainty [kNm]
Institute 0309	0,00	0,00	0,00	0,00
Institute 2707	0,00	0,00	0,00	0,00
Institute 3600	0,00	0,00	0,00	0,00
Institute 3605	0,00	0,00	0,00	0,00
Institute 3926	0,00	0,00	200,00	0,00
Institute 4253	0,00	0,00	0,00	0,00
Institute 4333	0,00	0,00	0,00	0,00
Institute 4652	0,00	0,00	0,00	0,00
Institute 4928	0,00	0,00	0,00	0,00
Institute 4956	0,00	0,00	200,00	0,00
Institute 4998	0,00	0,00	0,00	0,00
Institute 5144	0,00	0,00	0,00	0,00
Institute 5599	0,00	0,00	0,00	0,00
Institute 7646	0,00	0,00	0,00	0,00
Institute 7722	0,00	0,00	0,00	0,00
Institute 8418	0,00	0,00	200,00	0,00
Institute 8946	0,00	0,00	200,00	0,00
Institute 9328	0,00	0,00	0,00	0,00
Institute 9962	0,00	0,00	0,00	0,00

Deviation greater than limit, see also task007, chapter 3 'Pass / Fail Criteria'.

Note: Table 6-29: Uncertainty value is correct by the amount but positive instead of negative.

Table 6-29: Uncertainty, BIN 10 relative deviation to median

Uncertainties	BIN No. 10			
	Total uncertainty [kNm]	BIN scatter Uncertainty [kNm]	X-axis quantity Uncertainty [kNm]	BIN averaged mean values Uncertainty [kNm]
Institute 0309	0,00	0,00	0,00	0,00
Institute 2707	0,00	0,00	0,00	0,00
Institute 3600	0,00	0,00	0,00	0,00
Institute 3605	0,00	0,00	0,00	0,00
Institute 3926	0,00	0,00	200,00	0,00
Institute 4253	0,00	0,00	0,00	0,00
Institute 4333	0,00	0,00	0,00	0,00
Institute 4652	0,00	0,00	0,00	0,00
Institute 4928	0,00	0,00	0,00	0,00
Institute 4956	0,00	0,00	200,00	0,00
Institute 4998	0,00	0,00	0,00	0,00
Institute 5144	0,00	0,00	0,00	0,00
Institute 5599	0,00	0,00	0,00	0,00
Institute 7646	0,00	0,00	0,00	0,00
Institute 7722	0,00	0,00	0,00	0,00
Institute 8418	0,00	0,00	200,00	0,00
Institute 8946	0,00	0,00	200,00	0,00
Institute 9328	0,00	0,00	0,00	0,00
Institute 9962	0,00	0,00	0,00	0,00

Deviation greater than limit, see also task007, chapter 3 'Pass / Fail Criteria'.

Note: Table 6-29: Uncertainty value is correct by the amount but positive instead of negative.

6.8. Proficiency Test overall summary

14 out of 19 participants have passed all tasks, including the informative.

Table 6-30: Overview all tasks

	Institute 0309	Institute 2707	Institute 3600	Institute 3605	Institute 3926	Institute 4253	Institute 4333	Institute 4652	Institute 4928	Institute 4956	Institute 4998	Institute 5144	Institute 5599	Institute 7646	Institute 7722	Institute 8418	Institute 8946	Institute 9328	Institute 9962	
Capture Matrix	passed	passed	passed	passed	passed	passed	failed	failed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed
Load Statistics	passed	passed	passed	passed	passed	passed	failed	failed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed
Yaw Misalignment	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed
FFT	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed
Informative only / has to be discussed																				
Load Spectra	passed	passed	passed	passed	passed	passed	failed	failed	passed	passed	passed	passed	passed	passed	failed	passed	passed	passed	failed	passed
DEL	passed	passed	passed	passed	passed	passed	failed	failed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	failed
Uncertainties	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	failed	passed
Sum (excl. informative)	passed	passed	passed	passed	passed	passed	failed	failed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed
Sum (incl. informative)	passed	passed	passed	passed	passed	passed	failed	failed	passed	passed	passed	passed	passed	passed	failed	passed	passed	passed	failed	failed

“passed” = Applying the equation stated in the standard the values are negative in this case. Outliers where due to the “absolute function” of some participants where the result will be always positive. Due to the characteristics of uncertainty a positive value is correct as well.

“failed” = Task is failed
 “passed” = Task is passed

6.9. Proficiency Test informative tasks summary

15 out of 19 participants have passed the informative tasks.

Table 6-31: Overview informative tasks

	Institute 0309	Institute 2707	Institute 3600	Institute 3605	Institute 3926	Institute 4253	Institute 4333	Institute 4652	Institute 4928	Institute 4956	Institute 4998	Institute 5144	Institute 5599	Institute 7646	Institute 7722	Institute 8418	Institute 8946	Institute 9328	Institute 9962	
Load Spectra	passed	passed	passed	passed	passed	passed	failed	passed	passed	passed	passed	passed	passed	failed	passed	passed	passed	passed	failed	passed
DEL	passed	passed	passed	passed	passed	passed	failed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	failed
Uncertainties	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	failed	passed
Sum (only informative)	passed	passed	passed	passed	passed	passed	failed	passed	passed	passed	passed	passed	passed	failed	passed	passed	passed	passed	failed	failed

“passed” = Applying the equation stated in the standard the values are negative in this case. Outliers where due to the “absolute function” of some participants where the result will be always positive. Due to the characteristics of uncertainty a positive value is correct as well.

“failed” = Task is failed
 “passed” = Task is passed

6.10. Proficiency Test mandatory tasks summary

17 out of 19 participants have passed the mandatory tasks.

Table 6-32: Overview mandatory tasks

	Institute 0309	Institute 2707	Institute 3600	Institute 3605	Institute 3926	Institute 4253	Institute 4333	Institute 4652	Institute 4928	Institute 4956	Institute 4998	Institute 5144	Institute 5599	Institute 7646	Institute 7722	Institute 8418	Institute 8946	Institute 9328	Institute 9962		
Capture Matrix	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	
Load Statistics	passed	passed	passed	passed	passed	failed	failed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed
Yaw Misalignment	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed
FFT	passed	passed	passed	passed	passed	passed	failed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed
Sum (excl. informative)	passed	passed	passed	passed	passed	failed	failed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed	passed

“failed” = Task is failed

“passed” = Task is passed

7. IECRE Participants that passed the Proficiency Test

The following participants (in alphabetical order) are either IECRE RETLs or RETL candidates and have passed the Proficiency Test:

TESTING LABORATORY
Aresse Engineering S.L.
Barlovento Recursos Naturales S.L.
Beijing CGC Certification Center Co., Ltd.
China Classification Society Certification Co., Ltd. - CCSC
China Electric Power Research Institute - CEPRI
Deutsche WindGuard Consulting GmbH
DNV Energy Systems Germany GmbH
DNV Maritime and Energy, S.L.U.
DTU Wind Energy
Fraunhofer-Institut für Windenergiesysteme - IWES
Korea Institute of Energy Research
Nederlandse Organisatie voor Toegepast Natuurwetenschappelijk Onderzoek - TNO
Shanghai SERCAL New Energy Technology Co., Ltd.
UL International GmbH
Wind-consult GmbH
windtest grevenbroich gmbh

Note: This list **only contains the IECRE members (or in process of becoming so)** that have **passed** the Proficiency Test. Additional participants have passed it too, but they are not related to the IECRE system, and therefore not listed here.

The list reflects both the laboratories that have passed the second round of the Proficiency Test and those that have successfully completed the Correction Plan Phase. In order to improve the result analysis, tables in section 6 show the results of Round 2 **before** the correction plan phase. Thus, the number of successful participants does not match between section 6 and the current one.

8. Conclusions and recommendations after Round 1

See chapter Preliminary Line Choice.

9. Conclusions and recommendations after Round 2

In the informative annex B of the standard IEC61400-13, formula B.9 is the result not indicated as an absolute value. Within this Loads Proficiency Test there was the situation that some participant derived the correct value as negative (as per formula B.9) and some participant derived the exact same result but stated as positive (as absolute value of formula B.9).

An interpretation is that the uncertainty as a physical magnitude is always a positive value and as such, the absolute of the result might be presented when reporting the results. Although this has no effect to the following calculation sequence, this could be optimized to uniform these results according to the standard.

10. References

- [1] IEC 61400-13:2015, Measurement of mechanical loads.
- [2] IECRE OD-551-17, Edition 1.0, IECRE, 2020-08-17.